

ICC-ES Evaluation Report**ESR-3874 CBC Supplement***Issued October 2016**This report is subject to renewal October 2017.*www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION
Section: 07 81 00—Applied Fireproofing**REPORT HOLDER:****FLAMEOFF COATINGS, INC.**
800 ST. MARY'S STREET
RALEIGH, NC 27605
www.flameoffcoatings.com**EVALUATION SUBJECT:****FLAMEOFF FIRE BARRIER PAINT****1.0 REPORT PURPOSE AND SCOPE****Purpose:**

The purpose of this evaluation report supplement is to indicate that FlameOFF Fire Barrier Paint, recognized in ICC-ES master evaluation report ESR-3874, has also been evaluated for compliance with Sections 603.1 (Exception 21), 703.2, 704 and 803.1 of the code noted below.

Applicable code edition:

- 2016 California Building Code (CBC)

2.0 CONCLUSIONS

The FlameOFF Fire Barrier Paint, described in Sections 2.0 through 7.0 of the master evaluation report ESR-3874, complies with CBC Sections 603.1 (Exception 21), 703.2, 704 and 803.1, provided the design and installation are in accordance with the 2015 *International Building Code*® (IBC) provisions noted in the master report.

This supplement expires concurrently with the master report, issued October 2016.